

Government Of West Bengal Office Of The Divisional Fire Officer,North Dinajpur West Bengal Fire & Emergency Services Ralganj Fire Station, College Para, P.O.:- Ralganj, Pin :- 733134

Memo no.:IND/WB/FES/20192020/82643

Date: 05-09-2023

From:

Divisional Fire Officer, North Dinajpur West Bengal Fire & Emergency Services

To: Karnajora College of Education

Vill- Mehendigram, P.O.- Khalshi, P.S.- Raiganj, Dist.- Uttar Dinajpur.

Sub: Renewal Fire Safety Certificate for the Existing construction of G+2 storied building in the Name of KARNAJORA COL! EGE OF EDUCATION under group of Educational, at the premises no: Vill-Mehendigram, P.O-Khalshi, P.S-Ralganj, Dist-Uttar Dinajpur, Ralganj, Pin-733134.

This is in reference to your application no. 0125191230600056 dated 29-08-2023 regarding the Renewal Fire Safety Certificate for the Existing construction of G+2 storied building in the Name of KARNAJORA COLLEGE OF EDUCATION under group of Educational , at the premises no: Vill- Mehendigram, P.O- Khalshi , P.S- Raiganj , Dist- Uttar Dinajpur, Raiganj , Pin- 733134.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

(Terms and Condition) :-

- (1) Driveway/surrounding space of building must be free from any type of obstruction for easy movement of Fire appliances/ fire personnel at the time of exigency and No parking board will be allowed on the driveway.
- (2) To eliminate the risk of Fire hazards, good housekeeping for both inside and outside of the building will be strictly maintained.
- (3) Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building and to keep those in perfectly good working condition at all the times and it should be written in the Register.
- (4) Existing electrical wiring and installation of whole building/ specific place should be carefully checking and

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number: 0125191230600056.

maintenance regular by a licensed electrician.

- (5)Regular mock fire practice and evacuation drill should be conducted periodically by participation of all the occupants of the building.
- (6) The employees and security staff be conversant with installed firefighting equipment of the building and to operate in the event of fire and testing.
- (7) The entire fire fighting extinguishers should be tested once in a year.
- (8) Periodical flashing of water from the installing fire hydrant, sprinkler (if available as per FSR) should be making to maintain the efficient working performance.
- (9) The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
- (10) The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the Percolation of smoke as per FSR (if any).
- (11) As per issued FSR Fire Safety Recommendation, all pumps such as main pump, standby pump, along with jockey pump, terrace booster, pump (If any), and adequate first-Ald fire fighting device such as different type of fire extinguishers, hose reel along with others fire suppression systems always have to be kept ready in activated position.
- (12) A crew of trained fireman/ fire fighting staff under the experience officer to be kept ready in the premises and proper maintained the inbuilt and available fire fighting equipments / goars round the clock for safety of the respective business Building.
- (13) A register for the recording of mock fire drill, evacuation drill, testing and checking of whole fire fighting, electrical installation & liable to produce the same to the authorized officer of this department on demand.
- (14) This Renewal Fire Safety Certificate is valid up to three year from the date of issue and has to be renewed continuously after every three year from West Bengal Fire & Emergency Services, certifying about the satisfactory services, performance of all the life & fire safety arrangements and installations of the existing building and premises.
- (15) Fire license to be obtained from The appropriate authority from this Department for storing of LPG cylinder, in which attracts U/S Sec 12 of West Bengal Fire Service Act' 1950 with up to date amendment.

Signature valid

Digitally Signed
Name SWAPAN AUMY JAS
Date 08-809-2024 JAS
Rasion: Approved
Reason: Approved
Locatory Wash Bengul

Divisional Fire Officer, North Dinajpur West Bengal Fire & Emergency Services